


**SUMMARY OF RESULTS  
OF TESTING CERTIFICATE 0992 / 31.08.2009**

<b>NUMBER</b>	<b>0992</b>	<b>DATE</b>	<b>31 / 08 / 2009</b>
---------------	-------------	-------------	-----------------------

<b>Client' s data:</b>	<b>ETEM S.A.</b> <b>LIGHT METALS COMPANY</b> 1, IROON POLYTEHNIU STR. GR 196 00 MAGOULA ATTIKIS - GREECE
<b>Product description:</b>	<b>DOUBLE SASH WINDOW SLIDING</b>
<b>Material:</b>	<b>ALUMINIUM</b>
<b>System :</b>	<b>E - 22</b>



1280 x 1210mm

<b>Air Permeability</b> <i>ELOT EN 1026:2000 / ELOT EN 12207:2000</i>	<b>Class 3</b>
<b>Watertightness</b> <i>ELOT EN 1027:2000 / ELOT EN 12208:2000</i>	<b>Class 1A</b>
<b>Resistance to Wind Load</b> <i>ELOT EN 12211:2000 / ELOT EN 12210:2000</i>	<b>Class C4</b>

THE RESULTS CONCERN EXCLUSIVELY THE ABOVE TESTED PRODUCT.



**SINOI PAPAPOPOULOU**  
**TECHNICAL MANAGER**



**IOANNIS GKERTSOS**  
**GENERAL MANAGER**

EXACT TRANSLATION FROM THE GREEK ORIGINAL